SIEMENS

Data sheet

6ES7512-1SK01-0AB0



SIMATIC DP, CPU 1512SP F-1 PN for ET 200SP, Central processing unit with Work memory 300 KB for program and 1 MB for data, 1st interface: PROFINET IRT with 3-port switch, 48 ns bit performance, SIMATIC Memory Card required, BusAdapter required for Port 1 and 2

General information	
Product type designation	CPU 1512SP F-1 PN
HW functional status	FS05
Firmware version	V2.9
Product function	
● I&M data	Yes; I&M0 to I&M3
 Module swapping during operation (hot swapping) 	Yes; Multi-hot swapping
Isochronous mode	Yes; Only with PROFINET; with minimum OB 6x cycle of 625 µs
Engineering with	
 STEP 7 TIA Portal configurable/integrated from version 	V17 (FW V2.9) / V13 SP1 Update 4 (FW V1.8) or higher
Configuration control	
via dataset	Yes
Control elements	
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
Input current	
Current consumption (rated value)	0.6 A
Current consumption, max.	0.9 A
Inrush current, max.	4.7 A; Rated value
² t	0.14 A ² ·s
Power	
Infeed power to the backplane bus	8.75 W
Power loss	
Power loss, typ.	5.6 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
 integrated (for program) 	300 kbyte
 integrated (for data) 	1 Mbyte
Load memory	
 Plug-in (SIMATIC Memory Card), max. 	32 Gbyte

Backup	Ver
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	48 ns
for word operations, typ.	58 ns
for fixed point arithmetic, typ.	77 ns
for floating point arithmetic, typ.	307 ns
CPU-blocks	
Number of elements (total)	4 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max. FB	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
Number range	0 65 535
• Size, max.	200 kbyte
FC	200 kbyte
Number range	0 65 535
Size, max.	200 kbyte
OB	200 kbyte
• Size, max.	200 kbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
	20
Number of delay alarm OBs	
Number of cyclic interrupt OBs	20; With minimum OB 3x cycle of 500 µs
Number of process alarm OBs	50
Number of DPV1 alarm OBs	3
Number of isochronous mode OBs	1
Number of technology synchronous alarm OBs	2
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; Available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 88 KB
Flag	ounters, DDs, and technology data (ares). 00 ND
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	o, o block memory bit, grouped into one block memory byte
Data DIUCKS	

 Retentivity adjustable 	Yes
	No
Retentivity preset Local data	
 per priority class, max. 	64 kbyte; max. 16 KB per block
	טא אטענג, וומא. דט ועט אבו אוטענג
Address area	2.049; mov. number of modules / submodules
Number of IO modules I/O address area	2 048; max. number of modules / submodules
Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	52 kbyte, All outputs are in the process image
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	o kuyle
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	o noyte
Number of subprocess images, max.	32
Address space per module	
Address space per module, max.	288 byte; For input and output data respectively
Address space per station	200 Syto, For input and output data respectively
Address space per station, max.	2 560 byte; for central inputs and outputs; depending on configuration; 2
· Address space per station, max.	048 bytes for ET 200SP modules + 512 bytes for ET 200AL modules
Hardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration
·····	of distributed I/O via PROFINET or PROFIBUS communication
	modules, but also by the connection of I/O via AS-i master modules or
Number of DP mactore	links (e.g. IE/PB-Link)
Number of DP masters	1
Via CM	1
Number of IO Controllers integrated 	1
Via CM	0
Rack	
Modules per rack, max.	80; CPU + 64 modules + server module (mounting width max. 1 m) + 16
	ET 200AL modules
 Quantity of operable ET 200SP modules, max. 	64
Quantity of operable ET 200AL modules, max.	16
 Number of lines, max. 	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of
	available slots
Time of day	
Clock	
• Туре	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
 Deviation per day, max. 	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
 supported 	Yes
● to DP, master	Yes; Via CM DP module
● to DP, slave	Yes; Via CM DP module
• in AS, master	Yes
• in AS, slave	Yes
on Ethernet via NTP	Yes
Interfaces	
Number of PROFINET interfaces	1
Number of PROFIBUS interfaces	1; Via CM DP module
Optical interface	Yes; via BusAdapter
1. Interface	
Interface types	

RJ 45 (Ethernet)	Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45
Number of ports	3; 1. integr. + 2. via BusAdapter
integrated switch	Yes
BusAdapter (PROFINET)	Yes; compatible BusAdapters: BA 2x RJ45, BA 2x FC, BA 2x M12
Protocols	Tes, compatible bushdapters. DA 2X 1040, DA 2X 10, DA 2X 1112
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— Isochronous mode	Yes
— Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
— Prioritized startup	Yes; Max. 32 PROFINET devices
— Number of connectable IO Devices, max.	128; In total, up to 512 distributed I/O devices can be connected via AS- i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
 — Number of connectable IO Devices for RT, max. 	128
— of which in line, max.	128
 — Number of IO Devices that can be 	8; in total across all interfaces
simultaneously activated/deactivated, max.	
 Number of IO Devices per tool, max. 	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	250 μs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 μs of the isochronous OB is decisive
 for send cycle of 250 μs for send cycle of 500 μs 	250 μ s to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 μ s of the isochronous OB is decisive 500 μ s to 8 ms
	minimum update time of 500 μs of the isochronous OB is decisive
— for send cycle of 500 µs	minimum update time of 500 μs of the isochronous OB is decisive 500 μs to 8 ms
for send cycle of 500 μsfor send cycle of 1 ms	minimum update time of 500 μs of the isochronous OB is decisive 500 μs to 8 ms 1 ms to 16 ms
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625
 for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms
 for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT 	minimum update time of 500 μs of the isochronous OB is decisive 500 μs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)
 for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 μs 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms
 for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 μs for send cycle of 500 μs 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms
 for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 μs for send cycle of 500 μs for send cycle of 1 ms 	minimum update time of 500 μ s of the isochronous OB is decisive 500 μ s to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μ s: 375 μ s, 625 μ s 3 875 μ s) 250 μ s to 128 ms 500 μ s to 256 ms 1 ms to 512 ms
 for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 μs for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms 	minimum update time of 500 μ s of the isochronous OB is decisive 500 μ s to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μ s: 375 μ s, 625 μ s 3 875 μ s) 250 μ s to 128 ms 500 μ s to 256 ms 1 ms to 512 ms 2 ms to 512 ms
 for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 μs for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms 	minimum update time of 500 μ s of the isochronous OB is decisive 500 μ s to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μ s: 375 μ s, 625 μ s 3 875 μ s) 250 μ s to 128 ms 500 μ s to 256 ms 1 ms to 512 ms
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms 	minimum update time of 500 μ s of the isochronous OB is decisive 500 μ s to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 μ s: 375 μ s, 625 μ s 3 875 μ s) 250 μ s to 128 ms 500 μ s to 256 ms 1 ms to 512 ms 2 ms to 512 ms
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms
 for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 μs for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services PG/OP communication 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms 4 ms to 512 ms
 for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 μs for send cycle of 500 μs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services — PG/OP communication — Isochronous mode	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms 4 ms to 512 ms 4 ms to 512 ms
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services PG/OP communication Isochronous mode IRT 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms Yes No Yes No Yes
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services PG/OP communication Isochronous mode IRT PROFInergy 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms Yes No Yes; per user program
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services PG/OP communication Isochronous mode IRT PROFInergy Shared device Number of IO Controllers with shared device, 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms Yes No Yes No Yes
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services — PG/OP communication — IRT — PROFInergy — Shared device	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms Yes Yes Yes; per user program Yes 4
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services PG/OP communication Isochronous mode IRT PROFInergy Shared device Number of IO Controllers with shared device, max. 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms 4 ms to 512 ms 4 ms to 512 ms Yes No Yes Yes; per user program Yes
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services PG/OP communication Isochronous mode IRT PROFInergy Shared device Number of IO Controllers with shared device, max. activation/deactivation of I-devices 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms 4 ms to 512 ms Yes Yes; per user program Yes 4 Yes; per user program
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services PG/OP communication Isochronous mode IRT PROFIenergy Shared device Number of IO Controllers with shared device, max. activation/deactivation of I-devices Asset management record 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms 4 ms to 512 ms Yes Yes; per user program Yes 4 Yes; per user program
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services PG/OP communication Isochronous mode IRT PROFIenergy Shared device Number of IO Controllers with shared device, max. activation/deactivation of I-devices Asset management record 	minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs) 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms 4 ms to 512 ms Yes Yes; per user program Yes 4 Yes; per user program
 for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 4 ms With IRT and parameterization of "odd" send cycles Update time for RT for send cycle of 250 µs for send cycle of 500 µs for send cycle of 1 ms for send cycle of 2 ms for send cycle of 2 ms for send cycle of 4 ms PROFINET IO Device Services PG/OP communication Isochronous mode IRT PROFInergy Shared device Number of IO Controllers with shared device, max. activation/deactivation of I-devices Asset management record 	<pre>minimum update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms 4 ms to 64 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3 875 µs)</pre> 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program

Protocols	
PROFIBUS DP master	Yes
PROFIBUS DP master PROFIBUS DP slave	Yes
SIMATIC communication	Yes
PROFIBUS DP master	40. Of which 4 coop reconved for EC and LIMI
Number of connections, max.	48; Of which 4 each reserved for ES and HMI
 Number of DP slaves, max. 	125; In total, up to 512 distributed I/O devices can be connected via AS- i. PROFIBUS or PROFINET
Services	
— PG/OP communication	Yes
— Equidistance	No
— Isochronous mode	No
 Activation/deactivation of DP slaves 	Yes
	Tes
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
 Autonegotiation 	Yes
Autocrossing	Yes
Industrial Ethernet status LED	Yes
RS 485	
Transmission rate, max.	12 Mbit/s
Protocols	
PROFIsafe	Yes; V2.4 / V2.6
Number of connections	
 Number of connections, max. 	128; via integrated interfaces of the CPU and connected CPs / CMs
 Number of connections reserved for ES/HMI/web 	10
 Number of connections via integrated interfaces 	88
 Number of connections per CP/CM 	32
 Number of S7 routing paths 	16
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— Media redundancy	Yes; only via BusAdapter
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP
	Manager; MRP Client
 MRP interconnection, supported 	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
 — Switchover time on line break, typ. 	200 ms; For MRP, bumpless for MRPD
 Number of stations in the ring, max. 	50
SIMATIC communication	
 PG/OP communication 	Yes; encryption with TLS V1.3 pre-selected
 S7 routing 	Yes
Data record routing	Yes
S7 communication, as server	Yes
 S7 communication, as client 	Yes
• User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
— several passive connections per port,	Yes
supported	
 ISO-on-TCP (RFC1006) 	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; Max. 5 multicast circuits
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes

Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
Runtime license required	Yes
OPC UA Client	Yes
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Rsa15,
— User authentication	"anonymous" or by user name & password
- Number of connections, max.	4
 — Number of nodes of the client interfaces, max. 	1 000
 — Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/C max. 	300
 — Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. 	20
 — Number of elements for one call of OPC_UA_MethodGetHandleList, max. 	100
 — Number of simultaneous calls of the client instructions per connection (except OPC_UA_ReadList,OPC_UA_WriteList,OPC_UA_M max. 	1
 — Number of simultaneous calls of the client instructions 	5
OPC_UA_ReadList,OPC_UA_WriteList and OPC_UA_MethodCall, max.	
 Number of registerable nodes, max. 	5 000
 — Number of registerable method calls of OPC_UA_MethodCall, max. 	100
 — Number of inputs/outputs when calling OPC_UA_MethodCall, max. 	20
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
— Application authentication	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
— Number of sessions, max.	32
 Number of accessible variables, max. 	50 000
 Number of registerable nodes, max. 	10 000
 Number of subscriptions per session, max. 	20
— Sampling interval, min.	100 ms
— Publishing interval, min.	500 ms
Number of server methods, max.	20
 — Number of inputs/outputs per server method, max. 	20
— Number of monitored items, max.	1 000; for 1 s sampling interval and 1 s send interval
— Number of server interfaces, max.	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
 — Number of nodes for user-defined server interfaces, max. 	1 000
Further protocols	
MODBUS	Yes; MODBUS TCP
S7 message functions	
Number of login stations for message functions, max.	32
Program alarms	Yes
Number of configurable program messages, max.	5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of loadable program messages in RUN, max. Test commissioning functions	2 500
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 5 engineering systems
Status block	Yes; Up to 8 simultaneously (in total across all ES clients)

Single step	No
Number of breakpoints	8
Status/control	
Status/control variable	Yes; without fail-safe
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of variables, max.	
— of which status variables, max.	200; per job
- of which control variables, max.	200; per job
Forcing	
• Forcing	Yes; without fail-safe
 Forcing, variables 	Peripheral inputs/outputs
 Number of variables, max. 	200
Diagnostic buffer	
• present	Yes
 Number of entries, max. 	1 000
— of which powerfail-proof	500
Traces	
 Number of configurable Traces 	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
ERROR LED	Yes
MAINT LED	Yes
 Monitoring of the supply voltage (PWR-LED) 	Yes
 Connection display LINK TX/RX 	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of
 Number of available Motion Control resources for technology objects 	the PLC program; selection guide via the TIA Selection Tool 800
Required Motion Control resources	
- per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
 Positioning axis — Number of positioning axes at motion control cycle of 4 ms (typical value) 	5
— Number of positioning axes at motion control	10
cycle of 8 ms (typical value)	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
• PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Highest safety class achievable in safety mode	
Performance level according to ISO 13849-1	PLe
• SIL acc. to IEC 61508	SIL 3
Probability of failure (for service life of 20 years and repa	ir time of 100 hours)
 Low demand mode: PFDavg in accordance with SIL3 	< 2.00E-05
 — High demand/continuous mode: PFH in accordance with SIL3 	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
 horizontal installation, min. 	-25 °C; No condensation

- horizontal installation, may	60 °C
horizontal installation, max.	
• vertical installation, min.	-25 °C; No condensation
vertical installation, max.	50 °C
Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes; incl. failsafe
— FBD	Yes; incl. failsafe
— STL	Yes
— SCL	Yes
— GRAPH	Yes
Know-how protection	
 User program protection/password protection 	Yes
 Copy protection 	Yes
Block protection	Yes
Access protection	
 protection of confidential configuration data 	Yes
 Protection level: Write protection 	Yes
 Protection level: Read/write protection 	Yes
 Protection level: Write protection for Failsafe 	Yes
 Protection level: Complete protection 	Yes
programming / cycle time monitoring / header	
lower limit	adjustable minimum cycle time
upper limit	adjustable maximum cycle time
Dimensions	
Width	100 mm
Height	117 mm
Depth	75 mm
Weights	
Weight, approx.	310 g
last modified:	4/1/2022 🖸